

SECTION 10155 - TOILET COMPARTMENTS

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes toilet compartments and screens as follows:
 - 1. Type: Steel, color-coated finish.
 - 2. Compartment Style: Floor anchored.
 - 3. Screen Style: Wall hung.
- B. Related Sections include the following:
 - 1. Division 10 "Toilet and Bath Accessories" for toilet paper holders, grab bars, and similar accessories.

1.3 SUBMITTALS

- A. Product Data: For each type and style of toilet compartment and screen specified. Include details of construction relative to materials, fabrication, and installation. Include details of anchors, hardware, and fastenings.
- B. Shop Drawings: For fabrication and installation of toilet compartment and screen assemblies. Include plans, elevations, sections, details, and attachments to other work.
- C. Samples for Initial Selection: Manufacturer's color charts consisting of sections of actual units showing the full range of colors, textures, and patterns available for each type of compartment or screen indicated.

1.4 PROJECT CONDITIONS

- A. Field Measurements: Verify dimensions in areas of installation by field measurements before fabrication and indicate measurements on Shop Drawings. Coordinate fabrication schedule with construction progress to avoid delaying the Work.

PART 2 - PRODUCTS

2.1 MANUFACTURERS

- A. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:
1. Accurate Partitions Corporation.
 2. All American Metal Corp.
 3. Ampco Products, Inc.
 4. General Partitions Mfg. Corp.
 5. Global Steel Products Corp.
 6. Hadrian Inc.
 7. Knickerbocker Partition Corporation.
 8. Partition Systems, Inc.; Columbia Partitions.

2.2 MATERIALS

- A. General: Provide materials that have been selected for surface flatness and smoothness. Exposed surfaces that exhibit pitting, seam marks, roller marks, stains, discolorations, telegraphing of core material, or other imperfections on finished units are unacceptable.
- B. Steel Sheets for Color-Coated Finish: Provide mill-phosphatized steel sheet that is leveled to stretcher-leveled flatness complying with the requirements of standards indicated below:
1. Electrolytically Zinc-Coated Steel Sheet: ASTM A 591 (ASTM A 591M), Class C, of the following minimum thicknesses:
 - a. Pilasters (Unbraced): 0.0478 inch (1.2 mm).
 - b. Panels and Screens: 0.0299 inch (0.75 mm).
 - c. Doors: 0.0299 inch (0.75 mm).
 - d. Tapping Reinforcement: 0.0747 inch (1.9 mm).
 2. Hot-Dip Galvanized or Galvannealed Steel Sheet: ASTM A 653 (ASTM A 653M), in manufacturer's standard coating designation and of the following minimum thicknesses:
 - a. Pilasters (Unbraced): 0.052 inch (1.3 mm).
 - b. Panels and Screens: 0.040 inch (1.0 mm).
 - c. Doors: 0.034 inch (0.85 mm).
 3. Tapping Reinforcement: 0.079 inch (2.0 mm).
- C. Core Material for Metal-Faced Units: Manufacturer's standard sound-deadening honeycomb of resin-impregnated kraft paper in thickness required to provide finished thickness of 1 inch (25 mm) minimum for doors, panels, and screens and 1-1/4 inches (32 mm) minimum for pilasters.
- D. Stirrup Brackets: Manufacturer's standard ear or U-brackets for attaching panels and screens to walls and pilasters of the following material:
1. Material: Stainless steel.
- E. Full-Height (Continuous) Brackets: Manufacturer's standard design for attaching panels and screens to walls and pilasters of the following material:
1. Material: Stainless steel.

- F. Hardware and Accessories: Manufacturer's standard design, heavy-duty operating hardware and accessories of the following material:
 - 1. Material: Stainless steel.
- G. Anchorages and Fasteners: Manufacturer's standard exposed fasteners of stainless steel or chrome-plated steel or brass, finished to match hardware, with theft-resistant-type heads. Provide sex-type bolts for through-bolt applications. For concealed anchors, use hot-dip galvanized or other rust-resistant, protective-coated steel.

2.3 FABRICATION

- A. General: Provide standard doors, panels, screens, and pilasters fabricated for compartment system. Provide units with cutouts and drilled holes to receive compartment-mounted hardware, accessories, and grab bars, as indicated.
- B. Metal-Faced Toilet Compartments and Screens: Pressure laminate seamless face sheets to core material and provide continuous, interlocking molding strip or lapped and formed edges. Seal corners by welding or clips. Grind exposed welds smooth.
- C. Floor-Anchored Compartments: Provide manufacturer's standard corrosion-resistant anchoring assemblies complete with threaded rods, lock washers, and leveling adjustment nuts at pilasters for structural connection to floor. Provide shoes at pilasters to conceal anchorage.
- D. Wall-Hung Screens: Provide units in sizes indicated of same construction and finish as compartment panels, unless otherwise indicated.
- E. Doors: Unless otherwise indicated, provide 24-inch- (610-mm-) wide in-swinging doors for standard toilet compartments and 36-inch- (914-mm-) wide out-swinging doors with a minimum 32-inch- (813-mm-) wide clear opening for compartments indicated to be handicapped accessible.
 - 1. Hinges: Manufacturer's standard self-closing type that can be adjusted to hold door open at any angle up to 90 degrees.
 - 2. Latch and Keeper: Recessed latch unit designed for emergency access and with combination rubber-faced door strike and keeper. Provide units that comply with accessibility requirements of authorities having jurisdiction at compartments indicated to be handicapped accessible.
 - 3. Coat Hook: Manufacturer's standard combination hook and rubber-tipped bumper, sized to prevent door from hitting compartment-mounted accessories.
 - 4. Door Bumper: Manufacturer's standard rubber-tipped bumpers at out-swinging doors or entrance screen doors.
 - 5. Door Pull: Manufacturer's standard unit that complies with accessibility requirements of authorities having jurisdiction at out-swinging doors. Provide units on both sides of doors at compartments indicated to be handicapped accessible.

2.4 ZINC- OR ZINC-ALLOY-COATED STEEL SHEET FINISHES

- A. General: Comply with NAAMM's "Metal Finishes Manual for Architectural and Metal Products" for recommendations relative to applying finishes.
- B. Color-Coated Finish: Provide manufacturer's standard baked finish complying with coating manufacturer's written instructions for pretreatment, application, baking, and minimum dry film thickness.
 - 1. Color: One color in each room as selected by Architect from manufacturer's full range of colors.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. General: Comply with manufacturer's written installation instructions. Install units rigid, straight, plumb, and level. Provide clearances of not more than 1/2 inch (13 mm) between pilasters and panels and not more than 1 inch (25 mm) between panels and walls. Secure units in position with manufacturer's recommended anchoring devices.
 - 1. Secure panels to walls and panels with not less than 2 stirrup brackets attached near top and bottom of panel. Locate wall brackets so holes for wall anchors occur in masonry or tile joints. Align brackets at pilasters with brackets at walls.
- B. Floor-Anchored Compartments: Set pilaster units with anchors penetrating not less than 2 inches (50 mm) into structural floor, unless otherwise indicated in manufacturer's written instructions. Level, plumb, and tighten pilasters. Hang doors and adjust so tops of doors are level with tops of pilasters when doors are in closed position.
- C. Screens: Attach with anchoring devices according to manufacturer's written instructions and to suit supporting structure. Set units level and plumb and to resist lateral impact.

3.2 ADJUSTING AND CLEANING

- A. Hardware Adjustment: Adjust and lubricate hardware according to manufacturer's written instructions for proper operation. Set hinges on in-swinging doors to hold open approximately 30 degrees from closed position when unlatched. Set hinges on out-swinging doors and swing doors in entrance screens to return to fully closed position.
- B. Provide final protection and maintain conditions that ensure toilet compartments and screens are without damage or deterioration at the time of Substantial Completion.

END OF SECTION 10155